

# Utah Department of Environmental Quality

## Division of Drinking Water

### Public Water System Inventory Report

Run Date:  
08/04/2011 01:01 pm

**PWS ID:** UTAH26077      **Name:** STRAWBERRY ADMIN SITE  
**Legal Contact:** USFS - UINTA-WASATCH-CACHE NF SO      **Rating:** Approved  
KIM MARTIN      **Rating Date:** 02/13/2001  
**Address:** 88 W 100 N      **Activity Status:** Active  
PROVO, UT 84601  
**Phone Number:** 801-342-5100  
**City Served (Area):**  
**County:** WASATCH COUNTY  
**System Type:** Non-community      **Last Inv Update:** 05/24/2011      **Avg Daily Prod:**  
**Activity Status Cd:** Active      **Last Snty Srv Dt:** 06/25/2008      **Total Dsgn Cap:**  
**Population:** 25      **Surveyor:** DWIGHT HILL      **Total Emerg Cap:**  
**Oper Period:** 6/15 to 9/30

Gal/Day    Gal/Min

### Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	MARTIN, KIM	FOREST ENGIN	801-342-5130		

### Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Commercial	Unknown	0	1
Residential	Unknown	0	8
			9    Total Svc Connections

### Storage

**Total Storage:** 24,000 GAL      **Number of Units:** 1      **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	STRAWBERRY ADMIN RESERVOIR	Ground	24,000 GAL	Fiberglass		A	NO

### Distribution System

Pump Type	Total Dyn Head ft H2O    P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
		No		

### Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	STRAWBERRY ADMIN WELL	Active	SP				Yes	GW	Seasonal	6/15 to 9/30	

\*Reports measured flow for wells, approved design capacity for all other sources.